

April 15, 1999

H 1076. FIRE MAINS COMPLY WITH BUILDING CODE. TO REQUIRE THAT FIRE SERVICE MAINS COMPLY WITH THE NORTH CAROLINA STATE BUILDING CODE. Amends GS 87-10(b) to provide that public utilities contractors constructing fire service mains for connection to fire sprinkler systems must terminate those lines at a flange, cap, plug, or valve inside the building one foot above the finished floor. All fire service mains must comply with Standard 24 of National Fire Protection Ass'n that is incorporated and made applicable by Vol. V of NC State Building Code. Effective Oct. 1, 1999.

Intro. by Cox.

Ref. to Ways & Means

GS 87

May 12, 1999

H 1076. FIRE MAINS COMPLY WITH BUILDING CODE. Intro. 4/15/99. Senate committee substitute makes the following changes to 1st edition. Makes technical changes only.

June 2, 1999

SL 1999-123 (H 1076). FIRE MAINS COMPLY WITH BUILDING CODE. AN ACT TO REQUIRE THAT FIRE SERVICE MAINS COMPLY WITH THE NORTH CAROLINA STATE BUILDING CODE. Summarized in *Daily Bulletin* 4/15/99 and 5/12/99. Enacted May 28, 1999. Effective Oct. 1, 1999.