

February 19, 2007

H 260. AUTOMATIC SPRINKLERS/RESIDENTIAL BUILDINGS. Filed 2/19/07. *TO DISAPPROVE THE ADMINISTRATIVE RULES GOVERNING AUTOMATIC SPRINKLER SYSTEMS IN CERTAIN BUILDINGS AND TO MANDATE THE BUILDING CODE COUNCIL TO ADOPT RULES TO REQUIRE AUTOMATIC SPRINKLER SYSTEMS IN CERTAIN RESIDENTIAL BUILDINGS.* Disapproves rules adopted by the North Carolina Building Code Council (NCBCC) on September 13, 2006, and approved by the Rules Review Commission on October 19, 2006. Directs the NCBCC to adopt rules or amend the State Building Code to require automatic sprinkler systems in residential buildings of more than two stories and containing more than 16 dwelling units built on or after the effective date of the rule or amendment.
Intro. by Goforth, Brubaker, J. Harrell, Yongue. UNCODIFIED